

```
C:\BACnetGW>dir
Volume in drive C is WIN_ME_E
Volume Serial Number is 1F22-7E00

Directory of C:\BACnetGW

11/22/2002  04:37p      <DIR>          .
11/22/2002  04:37p      <DIR>          ..
11/22/2002  06:54p                815,973 BGV3011_2.EXE
11/22/2002  03:48p                20,480 BGVerUp.exe
10/30/2002  09:36a                1,771,480 ps
          3 File(s)          2,607,933 bytes
          2 Dir(s)          919,089,152 bytes free

C:\BACnetGW>ping 192.168.0.1

Pinging 192.168.0.1 with 32 bytes of data:

Reply from 192.168.0.1: bytes=32 time<10ms TTL=64
Reply from 192.168.0.1: bytes=32 time<10ms TTL=64
Reply from 192.168.0.1: bytes=32 time<10ms TTL=64
Reply from 192.168.0.1: bytes=32 time<10ms TTL=64

Ping statistics for 192.168.0.1:
    Packets: Sent = 4, Received = 4, Lost = 0 (0% loss),
    Approximate round trip times in milli-seconds:
        Minimum = 0ms, Maximum = 0ms, Average = 0ms

C:\BACnetGW>BGVerUp 192.168.0.1

DBACS Version Up Tool(ver1.0)
Copyright(c) 2002 DAIKIN INDUSTRIES, LTD. All Rights Reserved.

Now connecting to the DBACS(192.168.0.1)
Now putting the file. This typically takes several minutes...
Putting the file is succeeded.
Now validating the transfered file. This typically takes a few minutes...
Validating the file is succeeded.
Transfer was succeeded!!!

--- Press any key ---

C:\BACnetGW>exit_
```